



EU DECLARATION OF CONFORMITY

HES Hacılar Elektrik San. ve Tic. A.Ş.
Erciyes Mah. Hes Cad. No:22 38210 Kayseri/TURKİYE

Our company named and located in above address is declaring all the following our products have been manufactured with respect to those mentioned standards and documents will meet the necessities of 2011/65/EU of the European Parliament and of the Council of 8 June 2011 directive / we declare that the directives are built to meet the requirements.

PRODUCT NAME, TYPE, MODEL & SERIAL NUMBER

Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U)
Cables with special fire performance - Flexible cables with halogen-free thermoplastic insulation, and low emission of smoke

H03Z1Z1-F, H03Z1Z1H2-F 300/300 V
H05Z1Z1-F, H05Z1Z1H2-F 300/500 V
032XZ1-F, 032XZ1H2-F 300/300 V
052XZ1-F, 052XZ1H2-F 300/500 V
CU/XLPE/LSZH 300/300 V
CU/XLPE/LSZH 300/500 V
YY LSZH, HSLH-OB, HSLH -OZ, HSLH -JB, HSLH-JZ 300/500 V

RELATED STANDARDS

EN 50525-3-11, BS EN 50525-3-11, TS 13751, EN 60228, EN 50525-1, EN 61034-2, EN 60332-1-2

APPLICATIONS

- HFFR Insulation cables; indoors and outdoors, in cable ducts, underground, in power or switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.
- With HFFRLS outer sheath cables, energy networks in refineries, mines, hotels, schools, tunnels, high constructions, hospitals, power plant, data processing centers, business centers where there is a risk of fire.

CONSTRUCTION OF THE CABLES

- 1- Flexible Copper Conductors
- 2- HFFR Insulation
- 3- HFFRLS Outer Jacket



10.01.2019
HES Hacılar Elektrik Sanayi ve Ticaret A.Ş.
İbrahim GÜVEN
Quality Management Manager