

**AT UYGUNLUK BEYANI  
(EU DECLARATION OF CONFORMITY)**

HES Hacılar Elektrik San. ve Tic. A.Ş.  
Erciyes Mah. Hes Cad. No:22 38210 Kayseri/TURKIYE

Yukarıda ismi ve adresi belirtilen firmamız, aşağıda belirtilen ürünlerimizin tamamının ilgili standartlara ve Avrupa Parlamentosu ve Konseyinin 8 Haziran 2011 tarihli, 2011/65/EU direktif/direktiflerinin gereklerini karşılayan belgelere uygun olarak üretildiğini beyan etmektedir.

Our company named and located in above address is declaring all the following our products have been manufactured with respect to those mentioned standards and documents will meet the necessities of 2011/65/EU of the European Parliament and of the Council of 8 June 2011 directive / We declare that the directives are built to meet the requirements.

**MAMÜLÜN ADI, TİPİ, MODELİ, SERİ NO:**

**PRODUCT NAME, TYPE, MODEL&SERIAL NUMBER**

Kablolar: Beyan gerilimi en çok 450/750 V olan – Termoplastik yalıtımlı – Bölüm 14: Halojensiz termoplastik yalıtımlı ve kılıflı bükülgən kablolər (kordonlar)

Cables of rated voltage up to and including 450/750 V and having thermoplastic insulation – Part 14: Flexible cables (cords), Insulated and sheathed with halogen-free thermoplastic compounds

H05Z1-U, H05Z1-K 300/500 V

H05Z1-U, H05Z1-K 300/500 V

U: Som İletken

U : Solid conductor

K: Bükülgən İletken

K: Fine stranded flexible conductor

H07Z1-U, H07Z1-R, H07Z1-K 450/750 V

H07Z1-U, H07Z1-R, H07Z1-K 450/750 V

U: Som İletken

U : Solid conductor

R: Örgülü Rijit İletken

R: Rigid stranded conductor

K: Bükülgən İletken

K: Fine stranded flexible conductor

**STANDARTLAR:**

**RELATED STANDARDS**

TS HD 21.15 S1 :2004

TS EN 50525-3-31

HD 21.15 S1 :2004

EN 50525-3-31

**KULLANILDIĞI YERLER:**

**APPLICATIONS**

Oteller, okullar, yüksek binalar, hastaneler, bilgi işlem merkezleri ve insanların yoğun olarak bulunduğu iş merkezleri ile yangına hassas bölgelerde kullanılır.

Used in energy Networks in refineries, mines, hotels, schools, tunnels, high constructions, hospitals, power plant, data processing centers, business center where there is a risk of fire.

**YAPISI:**

**STRUCTURE:**

1- Bükülgən Bakır İletken, Bir veya Çok Telli Bakır İletken

1- Wires figured as solid, stranded and fine stranded flexible conductors

2- HFFRLS İzole (Tip 1)

2- HFFRLS insulation (Type 1)



01.03.2018 A.S. KAYIT

HES Hacilar Elektrik Sanayi ve Ticaret A.Ş.

İbrahim GÜVEN

Kalite Müdürü

Quality Manager